



A
TYP **DETAIL-WATER SERVICE CONNECTION ASSEMBLY**
 NO SCALE

NOTES:

- 1) THIS DETAIL SHOWS A COMPLETE SERVICE CONNECTION ASSEMBLY. ANY ONE OF THE COMPONENTS OR A COMBINATION OF THE COMPONENTS MAY BE REQUIRED FOR A COMPLETE INSTALLATION OF THE SERVICE CONNECTION.
- 2) SERVICE LATERAL PIPE SHALL BE IPS POLYETHYLENE TUBING, MEETING ASTM-D2239, NSF APPROVED PE-3408, 200 PSI. ALL FITTINGS SHALL BE MUELLER COMPRESSION OR APPROVED EQUAL.
- 3) WATER SERVICE METERS PROVIDED AND INSTALLED BY THE CONTRACTOR, SHALL BE 5/8"x3/4" #25 BADGER METER WITH BRONZE BODY, CAST IRON BOTTOM PLATE, RTR DIGITAL TRANSMITTER REGISTER (U.S. GALLONS), IRON PIT TYPE ERT MODULE W/ MOUNTING ACCESSORIES, 6' WIRE LEAD, AND TORX TAMPER PROOF SCREW.

filename - plot scale -

SUNRISE ENGINEERING, INC.

CONSULTING ENGINEERS & LAND SURVEYORS

11 North 300 West
 WASHINGTON, UTAH 84780

TEL. (435) 652-8450
 FAX (435) 652-8416



**KCWCD MEADOW VIEW HEIGHTS AREA
 WATER IMPROVEMENTS PROJECT 2005**

WATER SERVICE METER EXHIBIT